

## CONDENSATION CONTROL

All refrigeration, chilled water and cold water pipework shall be insulated with the thickness of Armaflex required to prevent condensation occurring at the design conditions stated below.

<b>Design conditions</b>	Maximum Ambient Temperature	(°C) _____
	Minimum Line Temperature	(°C) _____
	Maximum Relative Humidity	(%) _____

<b>Pipework type</b>	Refrigeration Pipework	<input type="checkbox"/>
	Chilled Water Pipework	<input type="checkbox"/>
	Cold Water Pipework	<input type="checkbox"/>

<b>Insulation material</b>	Class O Armaflex	<input type="checkbox"/>
	NH/Armaflex	<input type="checkbox"/>
	HT/Armaflex	<input type="checkbox"/>

### Thickness of Armaflex

Thickness recommendations can be obtained from the Armacell Customer Services Department.

	6mm	9 mm	13 mm	19 mm	25 mm	32 mm
Thickness Code	D	F	H	M	R	T
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

### Installation procedure

The insulation material should be installed strictly in accordance with the Armaflex Installation Manual, published by Armacell UK Limited. A copy is available as a download on [armacell.com](http://armacell.com) or from Armacell Customer Services Department.